## NOTES:

- See other sections of these Specifications for related requirements, or Special. Provision if applicable.
- 2. The water service shall extend perpendicular to street center line except in cul-de-sacs, and the tap shall be at least 24" from any adjacent joint or service.
- 3. Flange gaskets shall be full face 1/8" thick cloth inserted rubber.
- 4. All bolts and nuts to have electrodeposited coatings of zinc. Bolts must be 5/8" x 3"L.
- 5. Meter register to be set for curbside reading.
- 6. Domestic service line from meter to house shall be sized to Plumbing Code requirements. Fire sprinkler service line sizing shall be approved by Fire Marshal.
- 7. Meter box requirements:

When meter box is in concrete, install 1/4" x 3" expansion joint material around outside of box. The joint material shall be flush with finished grade.

Meter box cover to be flush with finished grade when in concrete, and  $1/2^{\prime\prime}$  above grade in landscaped areas.

Do not notch out meter box or extension. Customer side plumbing shall exit under bottom of meter box or extension.

Meter boxes shall be a minimum 6" clear from adjacent meter boxes, top of "x" of driveway approaches, and sidewalk access ramps.

REVISED	CITY OF FULLERTON ENGINEERING DEPARTMENT	DRAWN D.J.B.
	2" RESIDENTIAL FIRE/DOMESTIC	DATE12-1-00
		STD. NO.
	SERVICE INSTALLATION	606
	APPROVED Salest Lades DATE 12/14/00	
	DIRÉCTOR OF ENGINEERING	2 of 2